

1512 S BATAVIA AVENUE
GENEVA, IL 60134
630-232-0104

An  ALION Technical Center

RIVERBANK.ALIONSCIENCE.COM

FOUNDED 1918 BY
WALLACE CLEMENT SABINE

Test Report

FOR: **Turf Design**
Elgin, IL

Sound Absorption
RAL™-A18-380

Page 1 of 8

CONDUCTED: 2018-11-20

ON: Port ceiling tiles, mixed configuration

TEST METHOD

Riverbank Acoustical Laboratories™ is accredited by the U.S. Department of Commerce, National Institute of Standards and Technology (NIST) under the National Voluntary Laboratory Accreditation Program (NVLAP) as an ISO 17025:2005 Laboratory (NVLAP Lab Code: 100227-0) and for this test procedure. The test reported in this document conformed explicitly with ASTM C423-17: "Standard Test Method for Sound Absorption and Sound Absorption Coefficients by the Reverberation Room Method." The specimen mounting was performed according to ASTM E795-16: "Standard Practices for Mounting Test Specimens During Sound Absorption Tests." A description of the measurement procedure and room specifications is available upon request.

DESCRIPTION OF THE SPECIMEN

The test specimen was designated by the manufacturer as Port ceiling tiles, mixed configuration. A full external visual inspection performed on the test specimen by Riverbank personnel verified the manufacturer's description.

Test Specimen

Trade Name:	Port
Materials:	Formed polyethylene terephthalate felt
Tile Dimensions:	16 @ 609.6 mm (24 in.) x 609.6 mm (24 in.)
Overall Thickness:	101.6 mm (4 in.)
Tile Wall Thickness:	5 mm (0.197 in.)
Weights:	Type A, 5 @ 4.08 kg (9 lbs)
	Type B, 4 @ 3.18 kg (7 lbs)
	Type C, 4 @ 1.59 kg (3.5 lbs)
	Type D, 2 @ 1.59 kg (3.5 lbs)
	Overall Weight @ 10.43 kg (23 lbs)

1512 S BATAVIA AVENUE
GENEVA, IL 60134
630-232-0104

An ALION Technical Center

RIVERBANK.ALIONSCIENCE.COM

FOUNDED 1918 BY
WALLACE CLEMENT SABINE

Test Report

Turf Design
2018-11-20

RAL™-A18-380
Page 2 of 8

Specimen Configuration

(test chamber east wall)

A	C	A	B
C	A	D	C
B	C	B	D
A	C	A	B

Physical Measures

Size: 2.44 m (96.0 in) wide by 2.44 m (96.0 in) long
Thickness: 0.1 m (4.0 in)
Weight: 10.43 kg (23 lbs)
Mass per Unit Area: 1.75 kg/m² (0.36 lbs/ft²)
Calculation Area: 5.946 m² (64 ft²)

Test Environment

Room Volume: 291.98 m³
Temperature: 20.3 °C ± 0.1 °C (Requirement: ≥ 10 °C and ≤ 5 °C change)
Relative Humidity: 62.85 % ± 0.5 % (Requirement: ≥ 40 % and ≤ 5 % change)
Barometric Pressure: 99.6 kPa (Requirement not defined)

1512 S BATAVIA AVENUE
GENEVA, IL 60134
630-232-0104

An ALION Technical Center

RIVERBANK.ALIONSCIENCE.COM

FOUNDED 1918 BY
WALLACE CLEMENT SABINE

Test Report

Turf Design
2018-11-20

RAL™-A18-380

Page 3 of 8




Figure 1 – Specimen mounted in test chamber, as viewed from southeast corner of test chamber




Figure 2 – Tile types A (upper left), B (upper right), C (lower left), and D (lower right)

1512 S BATAVIA AVENUE
GENEVA, IL 60134
630-232-0104

An  ALION Technical Center

RIVERBANK.ALIONSCIENCE.COM

FOUNDED 1918 BY
WALLACE CLEMENT SABINE

Test Report

Turf Design

2018-11-20

RAL™-A18-380

Page 4 of 8

MOUNTING METHOD

Type E-400 Mounting: The test specimen was mounted with an airspace behind it. The number designates the distance in mm from the exposed face of the test specimen to the test surface, rounded to the nearest integer multiple of 5. For the purposes of this report, the mounting designation uses the point on the specimen face where minimum overall thickness was measured for reference. Perimeter edges were sealed with metal framing.

TEST RESULTS

1/3 Octave Center

Frequency (Hz)	Total Absorption (m ²)	Total Absorption (Sabins)	Absorption Coefficient
100	4.72	50.83	0.79
** 125	6.84	73.67	1.15
160	5.14	55.34	0.86
200	5.89	63.42	0.99
** 250	5.75	61.94	0.97
315	4.91	52.87	0.83
400	4.59	49.40	0.77
** 500	5.36	57.69	0.90
630	5.89	63.42	0.99
800	5.83	62.80	0.98
** 1000	6.32	67.99	1.06
1250	6.38	68.68	1.07
1600	6.32	67.98	1.06
** 2000	6.29	67.69	1.06
2500	6.58	70.87	1.11
3150	6.58	70.82	1.11
** 4000	6.69	72.04	1.13
5000	6.99	75.28	1.18

SAA = 0.98

NRC = 1.00

1512 S BATAVIA AVENUE
GENEVA, IL 60134
630-232-0104

An ALION Technical Center

RIVERBANK.ALIONSCIENCE.COM

FOUNDED 1918 BY
WALLACE CLEMENT SABINE

Test Report

Turf Design

2018-11-20

RAL™-A18-380


Page 5 of 8

TEST RESULTS (Continued)

The sound absorption average (SAA) is defined in ASTM C423-17 Section 3.1.1 as the average, rounded to the nearest integer multiple of 0.01, of the sound absorption coefficients of a material for the twelve one-third octave bands from 200 Hz through 2500 Hz, inclusive.

The noise reduction coefficient (NRC) is defined from previous versions of ASTM C423 as the average of the sound absorption coefficients at 250 Hz, 500 Hz, 1000 Hz, and 2000 Hz, expressed to the nearest integer multiple of 0.05.


Tested by


Marc Sciaky
Experimentalist

Report by


Malcolm Kelly
Acoustician

Approved by


Eric P. Wolfram
Laboratory Manager

1512 S BATAVIA AVENUE
GENEVA, IL 60134
630-232-0104

An  ALION Technical Center

RIVERBANK.ALIONSCIENCE.COM

FOUNDED 1918 BY
WALLACE CLEMENT SABINE

Test Report


Turf Design
2018-11-20

RAL™-A18-380

Page 6 of 8

SOUND ABSORPTION REPORT

Port ceiling tiles, mixed configuration



SAA = 0.98

NRC = 1.00

1512 S BATAVIA AVENUE
GENEVA, IL 60134
630-232-0104

An ALION Technical Center

RIVERBANK.ALIONSCIENCE.COM

Test Report

FOUNDED 1918 BY
WALLACE CLEMENT SABINE

Turf Design
2018-11-20

RAL™-A18-380

Page 7 of 8

APPENDIX A: Extended Frequency Range Data

Specimen: Port ceiling tiles, mixed configuration (See Full Report)

The following non-accredited data were obtained in accordance with ASTM C423-17, but extend beyond the defined frequency range of 100Hz to 5,000Hz. These unofficial results are representative of the RAL test environment only and intended for research & comparison purposes.

1/3 Octave Band Center Frequency (Hz)	Total Absorption (Sabins)	Absorption Coefficient
31.5	9.68	0.15
40	6.24	0.10
50	7.29	0.11
63	21.85	0.34
80	13.33	0.21
100	50.83	0.79
125	73.67	1.15
160	55.34	0.86
200	63.42	0.99
250	61.94	0.97
315	52.87	0.83
400	49.40	0.77
500	57.69	0.90
630	63.42	0.99
800	62.80	0.98
1000	67.99	1.06
1250	68.68	1.07
1600	67.98	1.06
2000	67.69	1.06
2500	70.87	1.11
3150	70.82	1.11
4000	72.04	1.13
5000	75.28	1.18
6300	74.92	1.17
8000	77.39	1.21
10000	81.31	1.27
12500	85.26	1.33

1512 S BATAVIA AVENUE
GENEVA, IL 60134
630-232-0104

An ALION Technical Center

RIVERBANK.ALIONSCIENCE.COM

FOUNDED 1918 BY
WALLACE CLEMENT SABINE

Test Report

Turf Design
2018-11-20

RAL™-A18-380

Page 8 of 8

APPENDIX B: Instruments of Traceability

Specimen: Port ceiling tiles, mixed configuration (See Full Report)

<u>Description</u>	<u>Model</u>	<u>Serial Number</u>	<u>Date of Certification</u>	<u>Calibration Due</u>
System 1	Type 3160-A-4/2	3160-106968	2018-08-09	2019-08-09
Brue! & Kjaer Mic And Preamp A	Type 4943-B-001	2311428	2018-09-28	2019-09-28
Brue! & Kjaer Pistonphone	Type 4228	2781248	2018-08-06	2019-08-06
Omega Digital Temp., Humid. And Pressure Recorder	OM-CP-PRHTemp2000	P97844	2018-02-03	2019-02-03

END