

Test Report

SPONSOR: **TURF Design Inc.**
Elgin, IL

Sound Absorption
RAL™-A20-405

CONDUCTED: 2020-09-17

Page 1 of 10

ON: Block (LG) baffle (9 objects spaced 12 in. on center)

TEST METHODOLOGY

Riverbank Acoustical Laboratories™ is accredited by the U.S. Department of Commerce, National Institute of Standards and Technology (NIST) under the National Voluntary Laboratory Accreditation Program (NVLAP) as an ISO 17025:2017 Laboratory (NVLAP Lab Code: 100227-0) and for this test procedure. The test reported in this document conformed explicitly with ASTM C423-17: "Standard Test Method for Sound Absorption and Sound Absorption Coefficients by the Reverberation Room Method." The specimen mounting was performed according to ASTM E795-16: "Standard Practices for Mounting Test Specimens During Sound Absorption Tests." A description of the measurement procedure and room specifications are available upon request. The results presented in this report apply to the sample as received from the test sponsor.

INFORMATION PROVIDED BY SPONSOR

The test specimen was designated by the sponsor as Block (LG) baffle (9 objects spaced 12 in. on center). The following nominal product information was provided by the sponsor prior to testing. The accuracy of such sponsor-provided information can affect the validity of the test results.

Product Under Test

Trade Name: Block (LG)
Material: Polyethylene terephthalate felt
Manufacturer: TURF Design Inc.

SPECIMEN MEASUREMENTS & TEST CONDITIONS

Through a full external visual inspection performed on the test specimen, Riverbank personnel verified the following information:

Test Specimen

Material: Notched and folded semirigid felt paneling
Dimensions: 9 @ 138.1 mm (5.44 in.) wide by 2438 mm (96 in.) long
Thickness: 138.1 mm (5.44 in.)
Overall Weight: 23.93 kg (52.75 lbs)

Test Report

TURF Design Inc.
2020-09-17

RAL™-A20-405
Page 2 of 10

Physical Measurements (per object)

Dimensions: 0.14 m (5.437 in) wide by 2.44 m (96.0 in) long
Thickness: 0.14 m (5.437 in)
Weight: 2.66 kg (5.86 lbs)

Test Environment

Room Volume: 291.98 m³
Temperature: 22.3 °C ± 0.1 °C (Requirement: ≥ 10 °C and ≤ 5 °C change)
Relative Humidity: 58.0 % ± 0.2 % (Requirement: ≥ 40 % and ≤ 5 % change)
Barometric Pressure: 99.2 kPa (Requirement not defined)

Each sound absorbing object had an absorptive area (all exposed surfaces) of 1.39 m² (14.91 ft²). The total absorptive area (all exposed surfaces) of all sound-absorbing objects was 12.47 m² (134.20 ft²). The array of objects covered 6.28 m² (67.58 ft²) of the horizontal test surface (total treated area).

MOUNTING METHOD

Type J Mounting: The specimen is an array of 9 spaced sound absorbing baffles suspended from cables such that the closest face of the baffles is located approximately 1.37 m (53.75 in.) from the horizontal test surface. This approximates the mounting method of a typical ceiling baffle installation. The baffles were evenly distributed in a single row, spaced 305 mm (12 in.) on center.

Test Report

TURF Design Inc.
2020-09-17

RAL™-A20-405
Page 3 of 10



Figure 1 – Specimen mounted in test chamber



Figure 2 – Detail of specimen material

Test Report

TURF Design Inc.
2020-09-17

RAL™-A20-405
Page 4 of 10



Figure 3 – Underside of individual baffle


Test Report**TURF Design Inc.**
2020-09-17**RAL™-A20-405**
Page 5 of 10**TEST RESULTS**

Note: There is currently no standardized method for calculating Absorption Coefficients from spaced object absorbers. The sound absorption performance of spaced object absorbers should not be compared directly with specimens tested as a single rectangular area (e.g. mounting types A, E, etc.).

1/3 Octave Center Frequency (Hz)	Total Absorption		Absorption per Object	
	(m ²)	(Sabins)	(m ² / Object)	(Sabins / Object)
100	1.44	15.48	0.16	1.72
** 125	1.66	17.87	0.18	1.99
160	1.74	18.76	0.19	2.08
200	3.04	32.77	0.34	3.64
** 250	3.61	38.81	0.40	4.31
315	4.93	53.03	0.55	5.89
400	5.97	64.25	0.66	7.14
** 500	7.03	75.69	0.78	8.41
630	7.56	81.39	0.84	9.04
800	8.12	87.43	0.90	9.71
** 1000	8.28	89.16	0.92	9.91
1250	8.20	88.31	0.91	9.81
1600	9.00	96.86	1.00	10.76
** 2000	10.20	109.78	1.13	12.20
2500	10.63	114.43	1.18	12.71
3150	10.94	117.73	1.22	13.08
** 4000	10.93	117.70	1.21	13.08
5000	11.19	120.48	1.24	13.39

Tested by 
Marc Sciaky
Senior Experimentalist

Report by 
Malcolm Kelly
Test Engineer, Acoustician

Approved by 
Eric P. Wolfram
Laboratory Manager

1512 S BATAVIA AVENUE
GENEVA, IL 60134
630-232-0104

An ALION Technical Center

RIVERBANK.ALIONSCIENCE.COM

FOUNDED 1918 BY
WALLACE CLEMENT SABINE


Test Report

TURF Design Inc.
2020-09-17

RAL™-A20-405
Page 6 of 10

SOUND ABSORPTION REPORT

Block (LG) baffle (9 objects spaced 12 in. on center)



NVLAP LAB CODE 100227-0

RIVERBANK ACOUSTICAL LABORATORIES IS ACCREDITED BY NVLAP (LAB CODE 100227-0) FOR ACOUSTICAL TESTING SERVICES IN ACCORDANCE WITH ISO/IEC 17025:2017 AND FOR THIS PROCEDURE. THIS REPORT MUST NOT BE USED BY THE CLIENT TO CLAIM PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY RAL, NVLAP, NIST, OR ANY AGENCY OF THE U.S. GOVERNMENT. THIS REPORT SHALL NOT BE MODIFIED WITHOUT THE WRITTEN APPROVAL OF RAL. THE RESULTS REPORTED APPLY ONLY TO THE SPECIFIC SAMPLE SUBMITTED FOR TESTING; RAL ASSUMES NO RESPONSIBILITY FOR THE PERFORMANCE OF ANY OTHER SAMPLE.

Test Report

TURF Design Inc.
2020-09-17

RAL™-A20-405
Page 7 of 10

APPENDIX A: Extended Frequency Range Data

Specimen: Block (LG) baffle (9 objects spaced 12 in. on center) (See Full Report)

The following non-accredited data were obtained in accordance with ASTM C423-17, but extend beyond the defined frequency range of 100Hz to 5,000Hz. These unofficial results are representative of the RAL test environment only and intended for research & comparison purposes.

1/3 Octave Band Center Frequency (Hz)	Total Absorption		Absorption per Object	
	(m ²)	(Sabins)	(m ² / Object)	(Sabins / Object)
31.5	0.41	4.46	0.05	0.50
40	-0.70	-7.50	-0.08	-0.83
50	-0.80	-8.57	-0.09	-0.95
63	-0.20	-2.11	-0.02	-0.23
80	0.57	6.16	0.06	0.68
100	1.44	15.48	0.16	1.72
125	1.66	17.87	0.18	1.99
160	1.74	18.76	0.19	2.08
200	3.04	32.77	0.34	3.64
250	3.61	38.81	0.40	4.31
315	4.93	53.03	0.55	5.89
400	5.97	64.25	0.66	7.14
500	7.03	75.69	0.78	8.41
630	7.56	81.39	0.84	9.04
800	8.12	87.43	0.90	9.71
1000	8.28	89.16	0.92	9.91
1250	8.20	88.31	0.91	9.81
1600	9.00	96.86	1.00	10.76
2000	10.20	109.78	1.13	12.20
2500	10.63	114.43	1.18	12.71
3150	10.94	117.73	1.22	13.08
4000	10.93	117.70	1.21	13.08
5000	11.19	120.48	1.24	13.39
6300	11.36	122.25	1.26	13.58
8000	11.24	121.01	1.25	13.45
10000	11.06	119.02	1.23	13.22
12500	11.64	125.32	1.29	13.92

Test Report**TURF Design Inc.**
2020-09-17**RAL™-A20-405**
Page 8 of 10**APPENDIX B: Instruments of Traceability**

Specimen: Block (LG) baffle (9 objects spaced 12 in. on center) (See Full Report)

<u>Description</u>	<u>Model</u>	<u>Serial Number</u>	<u>Date of Certification</u>	<u>Calibration Due</u>
System 1	Type 3160-A-042	3160-106968	2020-06-26	2021-06-26
Bruel & Kjaer Mic And Preamp A	Type 4943-B-001	2311428	2019-09-27	2020-09-27
Bruel & Kjaer Sound Level Calibrator	Type 4230	861609	2019-11-19	2020-11-19
Omega Digital Temp., Humid. And Pressure Recorder	OM-CP-PRHTemp2000	P97844	2020-02-18	2021-02-18

APPENDIX C: Revisions to Original Test Report

Specimen: Block (LG) baffle (9 objects spaced 12 in. on center) (See Full Report)

<u>Date</u>	<u>Revision</u>
2020-09-22	Original report issued

END

SPONSOR: **TURF Design Inc.**
Elgin, IL

Report Referenced: **RAL™-A20-405**
Page 1 of 2

CONDUCTED: 2020-09-17

ON: Block (LG) baffle (9 objects spaced 12 in. on center) (See Full Test Report for Details)

Appendix D to ASTM C423 Sound Absorption Test

Non-standard calculation of equivalent NRC Rating and Absorption Coefficients from spaced absorbers

At this time ASTM C423 does not provide a standard method for determining absorption coefficients of spaced object absorbers. Tests of a set of sound absorbing objects spaced apart from each other will yield higher absorption rates than a specimen joined together as a single patch (A-Mount or E-Mount). For this reason it is unfair to provide NRC or absorption coefficient ratings for specimens that consist of a spaced set of absorbers. Despite this, the architectural industry has expressed great demand for a simple "single number" rating for these treatments. Likewise, acoustical consultants desire equivalent absorption coefficient data for use in acoustical modeling software. The following is an attempt to appease these demands until ASTM develops a standard method for calculation. Several alternate non-standard calculation methods are provided. Riverbank Acoustical Laboratories prefers method 1.

Method 1) Apparent Sound Absorption Coefficient calculated from total test surface area covered

The total sound absorption yielded by the specimen is divided by the total surface area of the test surface covered by the suspended baffles, including intermediate spaces. The baffle rigging covered 6.28 m² (67.58 ft²) of horizontal test surface area. With an extra 166.62 mm (6.56 in.) of width to account for the space between the tested array and what would be the next baffle in a larger array, the surface area comes to 6.68 m² (71.96 ft²). Apparent Noise Reduction Coefficient (NRC) rating and Sound Absorption Average (SAA) figures are calculated from this data based on the methods described in ASTM C423-17. This may be the most accurate method for comparing baffle arrays to ceiling tile products. The apparent sound absorption coefficient data can be assigned to a single horizontal surface or plane in acoustical modeling software for approximation of baffle array performance. Such approximations rely on the assumptions that baffle spacing is similar to that of the tested array across the entire surface, that the spacing between rows of baffles is negligibly small, and that the installation occurs over a perfectly reflective surface material.

Method 2) Apparent Sound Absorption Coefficient calculated from total exposed surface area of specimen

The total sound absorption yielded by the specimen is divided by the total surface area of all exposed specimen faces (1.39 m² (14.91 ft²) per baffle x 9 baffles = 12.47 m² (134.20 ft²) total surface area). Apparent Noise Reduction Coefficient (NRC) rating and Sound Absorption Average (SAA) figures are calculated from this data based on the methods described in ASTM C423-17. This method shows the actual absorption occurring at the exposed surfaces, but does not provide a fair comparison with materials mounted as a uniform patch (in A-mount or E-mount).

Method 3) Apparent Sound Absorption Coefficient calculated from one face per baffle

The total sound absorption yielded by the specimen is divided by the surface area of one side of one large face for each baffle in the specimen (0.337 m² (3.63 ft²) per baffle x 9 baffles = 3.03 m² (32.63 ft²) total surface area). Apparent Noise Reduction Coefficient (NRC) rating and Sound Absorption Average (SAA) figures are calculated from this data based on the methods described in ASTM C423-17. This method is favored by some material manufacturers since it yields very high NRC figures, but does not provide a fair comparison with other ceiling tile or wall panel products. Riverbank Acoustical Laboratories recommends that results obtained from this method be used for research and comparison purposes only; such results should not be used for marketed claims of product performance.

SPONSOR: **TURF Design Inc.**
CONDUCTED: 2020-09-17

Report Referenced: **RAL™-A20-405**
Page 2 of 2

Appendix D: Data Note: See full test report for details of mounting position, spacing, and configuration, as these parameters greatly affect sound absorption performance.

Specimen Absorption			Method 1	Method 2	Method 3
Freq. (Hz)	Sabins	Sabins / Object	Apparent Abs. Coefficient From Total Coverage Area	Apparent Abs. Coefficient From Total Exposed Surface Area	Apparent Abs. Coefficient From One Face/Baffle
31.5	4.46	0.50	0.06	0.03	0.14
40	-7.50	-0.83	-0.10	-0.06	-0.23
50	-8.57	-0.95	-0.12	-0.06	-0.26
63	-2.11	-0.23	-0.03	-0.02	-0.06
80	6.16	0.68	0.09	0.05	0.19
100	15.48	1.72	0.22	0.12	0.47
125	17.87	1.99	0.25	0.13	0.55
160	18.76	2.08	0.26	0.14	0.57
200	32.77	3.64	0.46	0.24	1.00
250	38.81	4.31	0.54	0.29	1.19
315	53.03	5.89	0.74	0.40	1.63
400	64.25	7.14	0.89	0.48	1.97
500	75.69	8.41	1.05	0.56	2.32
630	81.39	9.04	1.13	0.61	2.49
800	87.43	9.71	1.22	0.65	2.68
1,000	89.16	9.91	1.24	0.66	2.73
1,250	88.31	9.81	1.23	0.66	2.71
1,600	96.86	10.76	1.35	0.72	2.97
2,000	109.78	12.20	1.53	0.82	3.37
2,500	114.43	12.71	1.59	0.85	3.51
3,150	117.73	13.08	1.64	0.88	3.61
4,000	117.70	13.08	1.64	0.88	3.61
5,000	120.48	13.39	1.67	0.90	3.69
6,300	122.25	13.58	1.70	0.91	3.75
8,000	121.01	13.45	1.68	0.90	3.71
10,000	119.02	13.22	1.65	0.89	3.65
12,500	125.32	13.92	1.74	0.93	3.84
Apparent NRC:			1.10	0.60	2.40
Apparent SAA:			1.08	0.58	2.38

Prepared by


Keith Kimberling
Test Engineer, Acoustician